

COOLING WATER TREATMENT CALCULATIONS										IMPORTANT NOTE			
1	CIR. RATE	M3/hr.	fill	10000	FILLING COLOUR CODE						FILL INPUT		
2	ΔT	deg.C		10							DO NOT FILL	calculations	
3	COC			5									
4	COC-1			4									
5	LEAK	M3/hr.		1									
6	JP CTSYSTEM	M3	M3	2000	FILL DATA								
7	Evaporation Rate	M3/hr.		185.19								M3/Hour	
8	Make Up Rate	M3/hr.	CLICK ONCE	231.48								M3/Hour	
9	Blow Down	M3/hr.		46.30								M3/Hour	
10	Drift Loss	M3/hr.		10								M3/Hour	
11	WASTAGE PER HOUR	M3/hr.		57.30								M3/Hour	
12	Wastage/Day	M3/Day		1375.11								M3/Day	
13	MAKE UP / DAY -	M3/D	m3/d	5556	166667	M3/MONTH						M3/Month	
14	Wastage/Month	m3/m		41253								M3/Month	
ANTISCALANT/ANTICORROSIVE DOSES										treatment on wastage		ANTI CORROSIVE SPECIAL	
15	ANTISCALANT/ANTICORROSIVE.	ppm	30	FILL DATA		ppm	25	icorrosive special					
16	15ppm to 50ppm			CLICK ONCE	41	LITERS/DAY		CLICK ONCE	34	LITERS/D			
17					1237.6	LITERS/MONTH			1031	LITERS/M			
18					14851.2	LITERS/YEAR			12376	LITERS/YR			
19	RATE	RS./USD/LIT	110	FILL RATE		RS./USD/LIT	100	FILL RATE					
20				CLICK ONCE	136136	RS/USDM		CLICK ONCE	103133	RS/USDM			
21					1633632	RS/USD/YR			1237600	RS/USD/YR			
22	DISPERSANT	ppm	10	FILL DATA	POLYMER	ppm	5	HOMO/COTER POLYMER					
23	5ppm to 20 ppm			CLICK ONCE	14	LITERS/DAY		CLICK ONCE	7	LITERS/D			
24					413	LITERS/MONTH			206	LITERS/M			
25					4950.4	LITERS/YEAR			2475.2	LITERS/YR			
26	RATE	RS./USD/LIT	120	FILL RATE		RS./USD/LIT	150	FILL RATE					
27				CLICK ONCE	49504	RS/USDM		CLICK ONCE	30940	RS/USDM			
28					594048	RS/USD/YR			371280	RS/USD/YR			
29	HOLD UP CTSYSTEM	M3	2000			M3	2000						
30	REDUCING BIOCID-1	ppm	30	FILL DATA	treatment on hold up	ppm	40	REDUCING BIOCID-2				ON HOLDUP	
31	30ppm to 100 ppm			CLICK ONCE	60	LITERS/INSTANCE		CLICK ONCE	80	LITER/INST			
32					instances/month	2			instances/month	2			
33					120	LITS/MONTH			160	LITS/M			
34					1440	LITS/YR.			1920	LITS/YR.			
35	RATE	RS./USD/LIT	200	FILL RATE		RS./USD/LIT	250	FILL RATE					
36				CLICK ONCE	24000	RS/USDM		CLICK ONCE	40000	RS/USDM			
37					288000	RS/USD/YR			480000	RS/USD/YR			
38	HOLD UP CTSYSTEM	M3	2000			M3	2000						
39	BIO DISPERSANT	ppm	10	FILL DATA	treatment on hold up	ppm	10	OXYDISING BIOCID-2				ON HOLD UP	
40	5 ppm to 30 ppm			CLICK ONCE	20	LITERS/INSTANCE		CLICK ONCE	20	LITERS/INST			
41					instances/month	2			instances/month	4			
42					40	LITS/YR.			80	LITS/M			
43					480	LITS/YR.			960	LITS/YR.			
44	RATE	RS./USD/LIT	300	FILL RATE		RS./USD/LIT	300	FILL RATE					
45				CLICK ONCE	12000	RS/USDM		CLICK ONCE	24000	RS/USDM			
46					144000	RS/USD/YR			288000	RS/USD/YR			
47	Make Up Rate	M3/hr.	231.48			Make Up Rate	M3/hr.	231.48					
48	OXYDISING BIOCID-2	ppm	2	FILL DATA	treatment on make up	ppm	5	FILL DATA					
49				CLICK ONCE	0.46	LIT/HR		CLICK ONCE	1.16	LIT/HR			
50					24	HOURS			24	HOURS			
51					11.1	HOURS/DAY			27.8	HOURS/D			
52					333	LITS/MONTH			833	LITS/M			
53					4000	LITS/YR.			10000	LITS/YR.			
54	RATE	RS./USD/LIT	70	FILL RATE		RS./USD/LIT	70	FILL RATE					
55				CLICK ONCE	23333	RS/USDMONTH		CLICK ONCE	58333	RS/USDM			
56					280000	RS/USD/YR			700000	RS/USD/YR			
57	TREATMENT COSTS										ONCE THROUGH SYSTEM		
58	MONTHLY	RS/USD		YEARLY	RS/USD	TREATMENT ON CIRCULATION RATE							
59	ANTISCALANT/ANTICOR.	136136		ANTICORROSIVE SPECIAL	103133	ANTICORROSIVE FILLING AMINE BASED							
60	DISPERSANT POLYMER	49504		HOMO/COTER POLYMER	30940	CIR. RATE	DOSE	3000	M3/HR.				
61	REDUCING BIOCID-1	24000		REDUCING BIOCID-2	40000	RATE	300	RS/USD/LIT					
62	BIO DISPERSANT	12000		OXYDISING BIOCID-2	24000	QUANTITY	PER DAY	72	LIT/DAY				
63	OXYDISING BIOCID-2	24000				PER MON.	2160	LIT/M					
64						PER YEAR	25920	LIT/YR.					
65						COST	PER YEAR	7776000	RS/USD				
66						OXYDISING BIOCID-2 CHLORINE ETC							
67						DOSE	0.5	PPM					
68						RATE	60	RS/KG					
69						QUANTITY	PER MON.	270	KG/M				
70						PER YEAR	3240	KG/YR.					
71						COST	PER YEAR	162000	RS/USD				
72	MONTHLY	501380		YEARLY	6016560								

by S.C.Bharadwaj.

COOLING TOW		CIRCULATION WATER		TREATMENT		SOFTWARE	
Designed parameters							
Cir.rate	M3/hr	to fill	93	M3/hr	TO		
			560		FILL		
delta T	deg.C.	to fill	6	deg.C.	UP		
COC		to fill	2		BLANKS		
			1		HAVING		
COC-1			4		COLOUR		
LEAK=0.1% OF CR.		0.1	0.093	M3/hr.	SHOWN		
Leak	%				BELOW		
CST SYSTEM	hM3	to fill	90	M3			
Process	Calculation			24 hours run			
E=CRXDELTA T/560			M3/hr	M3/DAY	M3/month		
Eva.Rate	M3/hr.		1.0	24			
M=E.x.COC/COC-1			M3/hr				
Make up	M3/hr.		2.0	48			
BD=M/COC			M3/hr				
Blow Down	M3/hr.		1.0	24			
DL=0.2% OF CR		0.2	100				
Drift loss	M3/hr.		0.186	4			
any LEAK	M3/hr		0.093				
total make up	M3/hr.		2.3	55		1636	
Treatment	Based	On 340 days	per year	wastage		18538	
PREPATED	BY	S.	C.	Bharadwaj			

Readsheet for the calculation of Ryzn

Input the data below:		
Parameter	Value	
Total Solids:	610	ppm as total solids
Temperature:	45	oC
Calcium Hardness:	230	ppm as CaCO3
Methyl Alkalinity:	90	ppm as CaCO3
pH	6.0	
Calculated Data:		
pHs	Saturation pH:	7.0
L	Langellier Index:	-1
R	Ryznar Index:	8
Calculation Details:		

Less than

Greater than

Langelier Index (L) = pH - pHS
 where:
 $9.3 + A + B - C - D$

	Value
A Function of TOTAL SOLIDS	610
B Function of TEMPERATURE	45
C Function of CALCIUM HARDNESS	230
D Function of ALKALINITY TO METHYL ORANGE	90
pH	6.0

pHS Saturation pH:
L Langellier Index:
R Ryznar Index:

TDS Total Solids ppm	Factor A	Water Temperature °C	Factor B	Calcium Hardness ppm CaCO3
100	0.1	0	2.6	10
4000	0.2	2	2.5	12
		7	2.4	14
		10	2.3	18
		14	2.2	23
		18	2.1	29
		22	2.0	35
		28	1.9	44
		32	1.8	56
		38	1.7	70
		44	1.6	88
		51	1.5	111
		57	1.4	139
		64	1.3	175
		72	1.2	230
				280
				350
				440
				560
				700
				880

Treatment On	Wastage	18538 M3/per year	On wastage	18538 M3/year
Antiscalant	Wastage to fill	55 M3/day	AntiCorrosive Cathodic/ Di.Anodic	55 M3/day
ppm	30	1.6 lit/day	25	1.4 lit/day
Range- 20 to 60 ppm		49.1 lit/month	ppm	40.9 lit/month
Rate .RS.	110 per lit.	556.2 lit/year	Rate.Rs.	463.5 lit/year
	monthly Rs.	5398 /month	100 Range-	30 to 80 ppm
	yearly Rs.	61177 /year	monthly Rs.	4089 /month
			yearly Rs.	46346 /year
Treatment On	continuous basis	M3/day	Treatment on continuous basis	
BASED ON	Hold up	90 M3	Hold up	90 M3

cts.ccc offer

BIOCIDE	NON OXY.	Biocide-1	90	NON OXY.	Biocide-2
ppm	30	21.6 lit/day		to fill	90 M3
Instances	8	172.8 lit/month		40	3.6 lit/day
Range-15 to 20 ppm		2073.6 lit/year		8	28.8 lit/month
Rate Rs.	300 per lit.			Range-15-100	345.6 lit/year
	monthly Rs.	51840 /month		250 Rate.Rs./lit	
	yearly Rs.	622080 /year		monthly Rs.	7200
				yearly Rs.	86400

Treatment	BASED ON	MAKE UP		SPECIAL	additive	
BIOCIDE	OXYDISING	Biocide	MAKE UP	Cl2/NaOCl/	ON HOLD UP	
	Cl2/NaOCl	48	M3/day	MAKE UP	to fill	90
ppm	ppm	15	0.717 lit/day		ppm	water
Instances	continuous		22 lit/month		10	90
Range-1 to 5 ppm			258 lit/year		Instances	0.9
Rate Rs.	IR/USD	70	3099		Rate Rs.	14.4
Residual-			monthly Rs.	1506.6	70 MONTHLY.Rs.	172.8
0.3 to 0.5 ppm			yearly Rs.	17074.8	Range-5 to 10	yearly.Rs.

SEA WATER	ONCE	THROUGH	CONTINUOUS	basis	Special	CONTINUOUS
BIOCIDE	OXYDISING	ClO2/O3			Poly Amine	93
Treatment	to fill	93	Cir.rate	LITER	M3/Hr	0.186
Range-0.5 to 2 ppm	0.5	93 M3/hr.		0.0465	ppm	5.58
		2232 M3/day		1.116	2	66.96
		66960 M3/month		33.48	continuous	Range-
Rate Rs.	70	803520 M3/year		401.76	Rate Rs.	100
	COST.Rs.	2343.6	monthly Rs.	2343.6		MONTHLY.Rs.
			yearly.Rs.	28123.2		yearly.Rs.

cts.ccc offer

cts.ccc offer

ALKALINITY			TOTAL		
pH	P	M	pH	P	M
7		3.5	9.7	180	1100
7.5		50	9.8	190	1150
7.8		100	9.9	200	1200
8		150	10	210	1250
8.3	5	200	10.1	220	1300
8.4	10	250	10.2	230	1350
8.5	20	300	10.3	240	1400
8.6	30	350	10.5	250	1500
8.7	40	400	10.6	300	1550
8.8	50	450	10.7	350	1600
9	60	500	10.8	400	1650
9	70	550	10.9	450	1700
9.1	80	600	11	500	1800
9.1	90	650			
9.2	100	700			
9.2	110	750			
9.3	120	800			
9.3	130	850			
9.4	140	900			
9.4	150	950			
9.5	160	1000			
9.6	170	1050			

by

S.C.

BHARADWAJ

formula	equql to	under root	Flow	divided by
pipe dia	18.826		2 x (M3/hr)	
mm.				

Hardness & Langellier Index

Less than 5.5 = scaling,

More than 6.5 = corrosive

8

Parameters	Make up	CTS water
	UG/Surface/	01/02/03
pH		
Alkalinity		
P		
M		
TH		
Ca		
Mg		
Cl		
SO4		
NO2/NO3		
PO4		

Function
0.1
1.6
2
2
7.0
-1
8

Negative = corrosive
Positive = scaling

SiO2
Fe
Cu
TDS
Sp.Cond.
TBC
SRB
E.Colie
Yeast/Funji
Algae
corrosion rate
LSI/RSI.

Factor C	Methyl Orange Alkalinity ppm CaCO3	Factor D	Conversion	Factors
0.6	10	1.0	Kg/CM2	1 Pounds/Inch2
0.7	12	1.1	Kg/CM2	10 MN/m2
0.8	14	1.2		
0.9	18	1.3	kW/hr	1 1.36hp hr.
1	22	1.4	Watt	1 1.36/1000 hp
1.1	29	1.5	HP hr.	1 736 Watt
1.2	36	1.6	Watt	1 0.86 kilocal/hr
1.3	45	1.8		
1.4	56	1.8	mg/lit	1 1 ppm
1.5	70	1.9	ppm	1 1000 ppb
1.6	88	2.0	% persant	1 10000 ppm
1.7	111	2.1	ntu/lit	1 1 ppm
1.8	140	2.2	ppb/lit	1 1000ppt
1.9	177	2.3	TR	100 67.2M3/hr
2.0	230	2.4	brine circula-	0.5 to 1.0 mtr/
2.1	280	2.5	tion in CCC.	second
2.2	360	2.6	Brine density	1.3 to1.6
2.3	450	2.7	brine flow	400 to 500
2.4	560	2.8		
2.5	700	2.9		
2.6	880	3.0	prepared by S.	C.

Anti Corrosive	On wastage	18538	On wastage	18538	M3/year
DISPERSANT	Dispersant	Mono Polyme Monomer	DISPERSANT	POLYMER	CoPolymer
On Hold up	55 M3/day		On Hold up	18538	
	to fill			to fill 18538	
ppm	10	0.5 lit/day	ppm	5	92.7
Range-		16 lit/month	Range-	ppm	2780.8
10 to 20 ppm		185 lit/year	10 to 15 ppm	Rate Rs.	31515
Rate.Rs.	120 per lit.		Rate.Rs.	120	
Treatment on	monthly Rs.	1963 /month	Treatment on	monthly Rs.	333690
continuous	yearly Rs.	22246 /year	continuous	yearly Rs.	3781824
Hold up	90 M3				

BIODISPERSANT	Cationic	Anionic
Bio Dispersant	90 M3	Non Ionic
ppm	10	0.9 lit/day
Instances	8	7 lit/month
Range-5 to 20 ppm		86 lit/year
Rate Rs.	300 per lit.	
	monthly Rs.	2160
	yearly Rs.	25920

Treatment	on	Shock	Basis
BASIS	Oxydising	Biocide	ON SHOCK ON HOLD UP
M3	/TTCA/	NaOBr/	ClO2/O3 Residual
OXY.BIOCIDE	M3	90	M3 ON HOLD UP
M3	ppm	10	0.9 lit/day
lit/day	Instance	4	3.6 lit/month
lit/month		to fill	43.2 lit/year
lit/year	Rate Rs.	125 per lit	1 to 2 ppm
1008	Range-	MONTHLY.Rs.	450 /month
12096	10 to 15 ppm	yearly.Rs.	5400 /year

BASED ON	CONTINUOUS basis		
Cir.rate	Filming	Amine	Range- 2 to 3 ppm
lit/day	to fill	Cir.rate	LITERS
lit/month	ppm	93	M3/Hr
lits/year	5	2232	M3/day 4.464
3 to 5 ppm		66960	M3/month 133.92
	Rs.	803520	M3/year 1517.76
31	Rate Rs.	500	MONTHLY.Rs 66960
374	Cost in Rs.		yearly Rs. 758880
prepared by	s.c.	Bharadwaj.	dt.03.11.16

cts.ccc offer

cts.ccc offer

velocity 2 to3 mtrs/sec		
CTS. Limit	CCC.(SRS)	CCC.Limits ambient/frez
CTS. Limit		09 to 10
8.5-9.0		80/100
500		500/600
300-500		<50
60% of TH		
40% of TH		
250		<0.5
300/750		250/350
NO3<10		500-800 NO2
01/05/20		01/05/20

150		100
0.5		0.5
0.2/0.5		0.2
1500/2500		1000/2000
1.5XTDS		1.5XTDS
100000/ml		100
100/100ml		1000
10/ml	nil	
slight	nd.	
slight	nd.	
0.2/0.5		0.2/0.5
RSI-6.0-5.0		RSI-6.0-5.0
14.22psi	pressure	
	1 pressure	
	energy	
	power	
	power	
	Heat flow	
parts per millicquantity		
parts per billion	1000 Ug/lit	
parts per millic per liter		
parts per liter	per liter	
parts per trialia	per liter	
	flow	
	velocity	
	sp.gr.	
M3/hr	flow	
Bharadwaj	dt.18.11.2016	
Terpolymer		
M3/day		
M3/day		
lit/day		
lit/month		
lit/year		
/month		
/year		

cts.ccc offer



COOLING TOVCIRCULATION WATER		
Designed parameters		
Cir.rate	M3/hr	to fill
delta T	deg.C.	to fill
COC		to fill
COC-1		
LEAK=0.1% OF CR.		0.1
Leak	M3/hr.	
CST SYSTEM hM3		to fill
Process	Calculation	
E=CRXDELTA T/560		560
Eva.Rate	M3/hr.	5 deg.C.
M=E.x.COC/COC-1		5
Make up	M3/hr.	1
BD=M/COC		4
Blow Down	M3/hr.	100 M3/hr.
DL=0.2% OF CR		0.2
Drift loss	M3/hr.	10
W=BD+DL+LEAK		2000 M3
		Grand Total
		89.3
	M3/DAY	M3/Month
	111.6	02679 80357
	22.3	
	100	
	20	
	10	

Treatment

Oxydising

Treatment

cts.ccc offer

cts.ccc offer

cts.ccc offer

SHEET	prepared	by-S.C.	Bharadwaj.
Cost	Calculated	in	IR/USD
Total	Cost	Monthly	Yearly
	IR/USD	5,397.93	61,176.57
		4,089.34	5,56,150.63
		1,962.88	22,246.03
	-1	#N/A	#N/A
	-2	7,200.00	86,400.00
		51,840.00	6,22,080.00
Shock		#N/A	#N/A
Continuous		monthly Rs.	yearly Rs.
Additive		0.00	to fill
IR/USD	#VALUE!	to fill	#N/A
IMP.	NOTES		
Colour		BLANKS	to fill
IGNORED	25 days	IN A YEAR	
against	Annual	Over Hall/	shut down
CONSIDERED		WORKING	PERIOD
Day	as 24	hours	
Month	as 30	days	

CLO2/O3
(eg.NaOCl)
lit/day
lit/month
lit/year
/month
/year

mg/lit	or	basis	Cathodic/
			M3
		Make up	
			00139
Based	on		M3/day
Biocide	on shock		
Based	on		

Treatment	chosen
Range	5 to 20 ppm
RATE	chosen
	Cost
Treatment	Based
Oxydising BiocCalculations	
(e.g.Chlorine) Cl2/NaOCL	
Treatment	chosen
Range	0.5 to 2 ppm
	choose the range
RATE	chosen
	Cost
Sea waterTreaThrough	
Oxydising BiocCalculations	
(e.g.Chlorine) Cl2/NaOCL	
Treatment	chosen
Range	0.5 to 2 ppm
	choose the range
RATE	chosen
	Cost
NOTE	ppm to


boiler.offer

	to fill	below	to fill	To fill	to fill	to fill
.....steaming..	M3/hour		50	100	150	500
.....steaming..	M3/day		1200	2400	3600	12000
Boiler Blow Down (CBD)	% of steaming		10	5	3	2
CBD loss	M3/hr			0	0	0
Make up	M3/day		120	120	108	10
Condensate Return in % of steaming	M3/hr					
	% of steaming	%	%	%	%	
	To fill		80	50	30	10
.....	M3/day		40	1200	1080	1200
Need based Blow Down if any	M3 /Day..... from lower ring header		5	4	3	1
Total Make up per day	M3/day					
Steaming rate total (cond.return +CBD+NBD)			1035	1076	2409	10789
WASTAGE						
	kg/cm2		Upto 20	Upto 40	Upto 60	Upto 80
TREATMENT BASED ON phosphate phosphonate dispersant	Blow Down M3/day		120	120	108	10
	ppm					
Cost Phosphate	Treatment based limit	Based on Na3PO4	Boiler Na3PO4	Blow Downs Na3PO4	Na3PO4	Na3PO4
As Product	To fill As PO4		30	20	12	6
	Hint Max.ppm		60	45	30	15
Na2SO3	Sulphite base ppm	Na2SO3	Na2SO3	Na2SO3	Na2SO3	Na2SO3
As Product	To fill As SO3		15	10	6	5
	Hint Max.ppm		48	32	16	8
Caustic Soda Soda Ash	Caustic based ppm	NaOH	NaOH	NaOH	NaOH	NaOH
As Product	To fill As CaCO3		5	4	3	2
	Hint Max.ppm		20	16	12	10
TREATMENT BASED ON WASTAGE	Total Waste M3/day	Treatment based N2H4	Based on N2H4	Total Waste of water N2H4	N2H4	N2H4
Hydrazine	To fill As N2H4.2H2O		5	4	3	2
As Product	Hint Max.ppm		24	20	16	8
Ammonia	To fill As NH4OH	based NH4OH	NH4OH	NH4OH	NH4OH	NH4OH
As Product	Hint Max.ppm		2	2	1	1
			10	10	10	10
Morpholine	To fill As Morpholine	C5H11NO Morpholine	Morpholine	Morpholine	Morpholine	Morpholine
As Product	Hint Max.ppm		3	3	4	4
			7.5	7.5	9	9
LIMITING PARAMTRS IN BOILER		RESIDUALS TO BE		MAINTAINED AS TESTED		

boiler.offer

pH			10 to11.5	10 to 11	10 to 10.5	9.5 to 10
ppm values	MF					
phosphate		1.5	20-40	15-30	5 to 20	5 to 10
PO4						
Sulphite		1.6	15-30	10 to 20	5 to 10	3 to 8
SO3						
Caustic		2		10	8	6
(2P-M)=OH						5
Hydrazine	total			12	10	8
Hydrazine	2 residual		0.1-1.0	0.1-0.5	0.05-0.3	0.03 to 0.05
N2H4						
Ammonia		2	5 to 10	5 to 8	5 to 6	4 to 5
NH3						
Morpholine		1.5	3 to 5	3 to 5	5 to 6	3 to 6
C5H11NO						
			DT.25.11.16. prepared by		S.C.	Bharadwaj

boiler.offer



COOLING TOWER	CIRCULATI WATER	TREATMENT	SOFTWARE	SHEET
Designed parameters			FINAL Treatment	Cost
Cir.rate	M3/hr	to fill	41000 M3/hr	Total
delta T	deg.C.	to fill	560	AntiScalant
COC		to fill	10 deg.C.	AntiCorrosive
COC-1			4	Dispersant
LEAK=0.1% OF CR.		0.1	1	Red.Biocides
Leak	M3/hr.		3	Red.Biocides
CST SYSTEM hold up	M3	to fill	100 M3/hr.	Biodispersant
			41	Oxy.Biocide
			8000 M3	Oxy.Biocide
				Shock
				Continuou
				Additive
Process	Calculation		Grand Total	IR/USD
E=CRXDELTA T/560				IMP.
Eva.Rate	M3/hr.		732.1	Colour
M=E.x.COC/COC-1			M3/DAY M3/Month	
Make up	M3/hr.		976.2 23429 702857	IGNORED
BD=M/COC				against
Blow Down	M3/hr.		244.0	CONSIDER
DL=0.2% OF CR		0.2	100	Day
Drift loss	M3/hr.		82	Month
W=BD+DL+LEAK			41	Year
Wastage	M3/hr.		367.0 08809	
Treatment	Based	on	Wastage 08809 M3/day	
Anti Scalant cum	Anti	Corrosive	Calculation	Anti
Treatment	chosen	ppm	to fill 30	Di
Range-15 to 50 ppm			264.3 lit/day	ppm
			7928.2 lit/month	
			89853.26 lit/year	
RATE	chosen	IR/USD	110 per lit.	IR/USD
	Cost	IR/USD	872105.1 /month	
		IR/USD	30550107 /year	
Treatment	Based	on	Wastage 08809 M3/day	
Dispersant	Polymer		Calculation	HomoPoly
Treatment	chosen	ppm	to fill 10	ppm
Range-5 to 20 ppm			88.1 lit/day	
			2642.7 lit/month	
			29951.1 lit/year	
RATE	chosen	IR/USD	120 per lit.	IR/USD
	Cost	IR/USD	317129.1 /month	
		IR/USD	3594130 /year	
Treatment	Based	on	Hold up 10000 M3	
Reducing Biocide-1			Calculation	Reducing
Treatment	chosen	ppm	to fill 30	ppm
Range-5 to 20 ppm		Instance	2	Instance
			300 lit/day	
			9000 lit/month	
			108000 lit/year	
RATE	chosen	IR/USD	200 per lit.	IR/USD
	Cost	IR/USD	1800000 /month	
		IR/USD	21600000 /year	

Treatment	Based on	Hold up	10000	M3	Oxydising
Bio Dispersant	Calculations	Cationic/ Anionic/	NonIonic		Cl2/NaOCl
Treatment	chosen	ppm	10	100 lit/day	ppm
Range-5 to 20 ppm		Instance	4	400 lit/month	Instance
				4800 lit/year	
RATE	chosen	IR/USD	300	per lit.	IR/USD
	Cost	IR/USD		120000 /month	
		IR/USD		1440000 /year	
Treatment	Based on	Make up	23429	M3/day	Special
Oxydising Biocide	Calculations	on	continuou	basis	Cl2/NaOCl
(e.g.Chlorine)	Cl2/NaOCl	TTCA/	to fill	ClO2/O3	
Treatment	chosen	ppm	0.5	11.7 lit/day	ppm
Range-0.5 to 2 ppm		continuous		351.4 lit/month	continuous
choose the range				4217.1 lit/year	
RATE	chosen	IR/USD	70	per lit.	IR/USD
	Cost	IR/USD		24600 /month	
		IR/USD		295200 /year	
Sea water Treat./Once Through	Cir.Rate	based	41000	M3/hr	Special
Oxydising Biocide	Calculation	on Circulation	Rate	basis	Poly
(e.g.Chlorine)	Cl2/NaOCl	TTCA/	to fill	ClO2/O3	
Treatment	chosen	ppm	0.5	492 lit/day	ppm
Range-0.5 to 2 ppm		continuous		14760 lit/month	continuous
choose the range				177120 lit/year	
RATE	chosen	IR/USD	70	per lit.	IR/USD
	Cost	IR/USD		1033200 /month	
		IR/USD		12398400 /year	
NOTE	ppm to	mg/lit	or	gms/ton/nor	kg/lit

prepared	by-S.C.	Bharadwaj.
Calculated	in	IR/USD
Cost	Monthly	Yearly
IR/USD	8,72,105.14	3,05,50,107.43
	0.00	0.00
	3,17,129.14	35,94,130.29
	18,00,000.00	2,16,00,000.00
	60,00,000.00	7,20,00,000.00
	1,20,000.00	14,40,000.00
	30,000.00	3,60,000.00
s	24,600.00	2,95,200.00
	2,46,000.00	29,52,000.00
	###	###

NOTES		
BLANKS		
		to fill
25 days	IN A YEAR	
Annual	Over Hall/	shut down
ED	WORKING	PERIOD
as 24	hours	
as 30	days	
as 340	days	

Corrosive	special	
Cathodic/	Di	Anodic
0		0.0 lit/day
		0.0 lit/month
		0 lit/year
0	per lit	
0.0 IR/USD		/month
0.0 IR/USD		/year

DiPoly/	Terpolymer	
to fill		
5		44.0 lit/day
		1321.4 lit/month
		14975.5 lit/year
120	per lit	
158564.6 IR/USD		/month
1797065.1 IR/USD		/year

Biocide-2		
to fill		
40		800 lit/day
2		24000 lit/month
		288000 lit/year
250	per lit.	
6000000 IR/USD		/month
72000000 IR/USD		/year

Biocide	on shock	basis
/TTCA/	NaOBr/	ClO2/O3
to fill		(e.g.ClO2)
2		4 lit/day
2		240 lit/month
		2880 lit/year
125	per lit	
30000	IR/USD	/month
360000	IR/USD	/year

additive	continuous	basis
/TTCA/	NaOBr/	ClO2/O3
to fill		(eg.NaOCl)
10		234.3 lit/day
		7028.571429 lit/month
		84342.85714 lit/year
80	per lit.	
562285.7	IR/USD	/month
6747428.6	IR/USD	/year

additive	continuous	basis
Amine/	Filming	Amine
to fill	e.g.Filming	Amine
2		82 lit/day
		2460 lit/month
		29520 lit/year
100	per lit.	
246000	IR/USD	/month
2952000	IR/USD	/year

1000 tons /m3
 prepared by s.c. Bharadwaj.



COOLING TOWER		CIRCULATING WATER		TREATMENT		SOFTWARE	SHEET
Designed parameters						FINAL Treatment	Cost
Cir.rate	M3/hr	to fill	41000 M3/hr				Total
delta T	deg.C.	to fill	560	10 deg.C.			
COC		to fill	4				
COC-1			1				-1
LEAK=0.1% OF CR.			3				-2
Leak	M3/hr.		0.1	100 M3/hr.			Shock
CST SYSTEM hold up	M3	to fill	8000 M3				Continuou
Process	Calculation					Grand Total	IR/USD
E=CRXDELTA T/560							IMP.
Eva.Rate	M3/hr.		732.1				
M=E.x.COC/COC-1				M3/DAY	M3/Month		Colour
Make up	M3/hr.		976.2	23429		702857	
BD=M/COC							IGNORED
Blow Down	M3/hr.		244.0				against
DL=0.2% OF CR			0.2	100			CONSIDER
Drift loss	M3/hr.		82				Day
W=BD+DL+LEAK			41				Month
Wastage	M3/hr.		367.0	08809			Year
Treatment	Based	on	Wastage	08809 M3/day			
Anti Scalant cum	Anti	Corrosive	Calculation				Anti
Treatment	chosen	ppm	to fill				Di
Range-15 to 50 ppm			30	264.3 lit/day			ppm
				7928.2 lit/month			
				89853.26 lit/year			
RATE	chosen	IR/USD	110	per lit.			IR/USD
	Cost	IR/USD		872105.1 /month			
		IR/USD		30550107 /year			
Treatment	Based	on	Wastage	08809 M3/day			
Dispersant	Polymer		Calculation				HomoPoly
Treatment	chosen	ppm	to fill				ppm
Range-5 to 20 ppm			10	88.1 lit/day			
				2642.7 lit/month			
				29951.1 lit/year			
RATE	chosen	IR/USD	120	per lit.			IR/USD
	Cost	IR/USD		317129.1 /month			
		IR/USD		3594130 /year			
Treatment	Based	on	Hold up	10000 M3			
Reducing Biocide-1			Calculation				Reducing
Treatment	chosen	ppm	to fill				ppm
Range-5 to 20 ppm			30	300 lit/day			
		Instance	2	9000 lit/month			Instance
				108000 lit/year			
RATE	chosen	IR/USD	200	per lit.			IR/USD
	Cost	IR/USD		1800000 /month			
		IR/USD		21600000 /year			

Treatment	Based on	Hold up	10000	M3	Oxydising
Bio Dispersant	Calculations	Cationic/ Anionic/	NonIonic		Cl2/NaOCl
Treatment	chosen	ppm	10	100 lit/day	ppm
Range-5 to 20 ppm		Instance	4	400 lit/month	Instance
				4800 lit/year	
RATE	chosen	IR/USD	300	per lit.	IR/USD
	Cost	IR/USD		120000 /month	
		IR/USD		1440000 /year	
Treatment	Based on	Make up	23429	M3/day	Special
Oxydising Biocide	Calculations	on	continuou	basis	Cl2/NaOCl
(e.g.Chlorine)	Cl2/NaOCl	TTCA/	to fill	ClO2/O3	
Treatment	chosen	ppm	0.5	11.7 lit/day	ppm
Range-0.5 to 2 ppm		continuous		351.4 lit/month	continuous
choose the range				4217.1 lit/year	
RATE	chosen	IR/USD	70	per lit.	IR/USD
	Cost	IR/USD		24600 /month	
		IR/USD		295200 /year	
Sea water Treat./Once Through	Cir.Rate	based	41000	M3/hr	Special
Oxydising Biocide	Calculation	on Circulation	Rate	basis	Poly
(e.g.Chlorine)	Cl2/NaOCl	TTCA/	to fill	ClO2/O3	
Treatment	chosen	ppm	0.5	492 lit/day	ppm
Range-0.5 to 2 ppm		continuous		14760 lit/month	continuous
choose the range				177120 lit/year	
RATE	chosen	IR/USD	70	per lit.	IR/USD
	Cost	IR/USD		1033200 /month	
		IR/USD		12398400 /year	
NOTE	ppm to	mg/lit	or	gms/ton/nor	kg/lit

prepared	by-S.C.	Bharadwaj.
Calculated	in	IR/USD
Cost	Monthly	Yearly
IR/USD	8,72,105.14	3,05,50,107.43
	0.00	0.00
	3,17,129.14	35,94,130.29
	18,00,000.00	2,16,00,000.00
	60,00,000.00	7,20,00,000.00
	1,20,000.00	14,40,000.00
	30,000.00	3,60,000.00
s	24,600.00	2,95,200.00
	2,46,000.00	29,52,000.00
	###	###

NOTES

BLANKS
 to fill

25 days | IN A YEAR

Annual | Over Hall/ | shut down

ED | WORKING | PERIOD

as 24 | hours |

as 30 | days |

as 340 | days |

Corrosive special

Cathodic/	Di	Anodic
0		0.0 lit/day
		0.0 lit/month
		0 lit/year
0	per lit	
0.0	IR/USD	/month
0.0	IR/USD	/year

DiPoly/ Terpolymer

to fill		
5		44.0 lit/day
		1321.4 lit/month
		14975.5 lit/year
120	per lit	
158564.6	IR/USD	/month
1797065.1	IR/USD	/year

Biocide-2

to fill		
40		800 lit/day
2		24000 lit/month
		288000 lit/year
250	per lit.	
6000000	IR/USD	/month
72000000	IR/USD	/year

Biocide	on shock	basis
/TTCA/	NaOBr/	ClO2/O3
to fill		(e.g.ClO2)
2		4 lit/day
2		240 lit/month
		2880 lit/year
125	per lit	
30000	IR/USD	/month
360000	IR/USD	/year

additive	continuous	basis
/TTCA/	NaOBr/	ClO2/O3
to fill		(eg.NaOCl)
10		234.3 lit/day
		7028.571429 lit/month
		84342.85714 lit/year
80	per lit.	
562285.7	IR/USD	/month
6747428.6	IR/USD	/year

additive	continuous	basis
Amine/	Filming	Amine
to fill	e.g.Filming	Amine
2		82 lit/day
		2460 lit/month
		29520 lit/year
100	per lit.	
246000	IR/USD	/month
2952000	IR/USD	/year

1000 tons /m3
 prepared by s.c. Bharadwaj.



COOLING TOWER SYSTEM MAKE UP AND WASTE WATER
CALCULATION SOFTWARE

FEATURES-

[1] Software is made ready with the object to calculate instantly on per month basis the quantity of Make and Waste water. It is an stepping stone for Treatment cost calculations.

[2] To get them quickly certain physical operating parameters like Circulation rate, delta T, Cycle of Concentration(COC) and System hold up volume values are entered in the blanks shown.

[3] Base data from per hour basis when filled, instantly per day and then per month consumption of Make and Waste water quantities are exhibited.

[3] So, there is no need to use calculator on daily basis.

[4] It can be made as a daily work sheet also. The SOFTWARE results shown, in the next steps can be utilized for the annual budget targeted vis a vis actual achievement in cost savings.

[5] There is one month guarantee for its normal functions and thereby a provision of free replacement. Finally, any modification subject to site conditions is a well come.

The software shall be amended accordingly and given back.

Let us then see, how much practical it shall be in meeting the target please.

With due regards.

S.C.Bharadwaj. Technical Advisor.
dt.23.01.2016.

GURGAON.
Haryana.(INDIA)

COOLING TOWER	CIRCULATION	WATER	TREATMENT
Designed parameters			
Cir.rate	M3/hr	to fill	4000
			560
delta T	deg.C.	to fill	5
COC		to fill	4
			1
COC-1			3
LEAK=0.1% OF CR.		100	0.1
Leak	M3/hr.		4
CST SYSTEM hold up	M3	to fill	1000
Process	Calculation		
E=CRXDELTA T/560			
Eva.Rate	M3/hr.		35.7
M=E.x.COC/COC-1			
Make up	M3/hr.		47.6
BD=M/COC			MAKE UP
Blow Down	M3/hr.		11.9
DL=0.2% OF CR		0.2	100
Drift loss	M3/hr.		8
W=BD+DL+LEAK			Wastage
Wastage	M3/hr.		23.9
Wastage	M3/year		Wastage
Hours of run per day		24 for yearly days	340
Days in a month		30	
PREPATED	BY	S.	C.

SOFTWARE

M3/hr	TO FILL UP BLANKS HAVING COLOUR SHOWN BELOW
deg.C.	
M3/hr.	
M3	

make up M3/DAY	make up M3/Mon.
01143	34285.71
388571.42857143	PER YEAR
wastage M3/DAY	wastage M3/Mon.
00574	17211.43
195063	PER YEAR
	M3/year

Bharadwaj tech.advr. 01/10/15